

1

機種名 _____

仕様

防振材	スプリング (NS250-20)
-----	------------------

表面処理	溶融亜鉛めっき
------	---------

耐震基準	ストッパーボルト	2.0G
------	----------	------

機器固定ボルト 溶融亜鉛めっき

[illegible]

系統名

殿

Technical drawing of a rectangular plate with dimensions and a label. The plate has a total width of 900 (100 + 790 + 100) and a total height of 420 (30 + 360 + 30). There are four anchor bolt holes, labeled "アンカーボルト孔 (4-φ16)", located at the corners of the plate. The distance between the center of the anchor bolt holes is 790 horizontally and 360 vertically. The distance from the center of the anchor bolt holes to the edge of the plate is 100 horizontally and 30 vertically.

1. 防振架台の据付は下部ベース全面で受けるようにして下さい。
また、水平面に設置し、架台シールに基づき確実に据付けて下さい。
(上部ベースに「正面側」、「配管側」などのシールが貼ってあります)
2. レベル調整は防振材の移動となります。
3. アンカーボルトは含まれておりませんので、先様にてご用意下さい。
4. 機器設置後に ①、② 共に1~2mm程度隙間をあけて下さい。
5. 防振材の仕様は場合により変更する事があります。

[illegible]

番号	日付	改訂記事
----	----	------

△	' 13. 01. 29	仕様追加、図枠張替、架台高さ変更
---	--------------	------------------

承認日	承認	設計	作図
-----	----	----	----

09.11.09	小林	小林	鈴木由
----------	----	----	-----

不ミ一株式会社


NEMO **INM**

Nemy foundation system

No.	1	MDI 207
-----	---	---------

No.	1-MDL207
-----	----------